

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE		PAGE OF PAGES	
2. AMENDMENT/MODIFICATION NO.		3. EFFECTIVE DATE		4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO. (If applicable)	
6. ISSUED BY		CODE		7. ADMINISTERED BY (If other than Item 6)		CODE	
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)				(X)		9A. AMENDMENT OF SOLICITATION NO.	
						9B. DATED (SEE ITEM 11)	
						10A. MODIFICATION OF CONTRACT/ORDER NO.	
						10B. DATED (SEE ITEM 11)	
CODE		FACILITY CODE					

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

- ☐ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ☐ is extended, ☐ is not extended.
- Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:
- (a) By completing items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted;
- or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

**13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS.
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor ☐ is not, ☐ is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA	16C. DATE SIGNED
_____ (Signature of person authorized to sign)		_____ (Signature of Contracting Officer)	

U.S. DEPARTMENT OF TRANSPORTATION
FEDERAL HIGHWAY ADMINISTRATION
EASTERN FEDERAL LANDS HIGHWAY DIVISION

Amendment 002
Blue Ridge Parkway
Project PRA-BLRI 2P14
DTFH71-08-R-00014

The purpose of this Amendment is to:

- 1) Revise the Special Contract Requirements (J pages) as follows:
 - a) Section 108 to clarify pavement removal and placement of asphalt pavement requirements.
 - b) Section 304 to clarify aggregate cement mixtures compaction and finishing time requirements.
- 2) Revise the Plans to replace traffic control notes sheet to clarify and add traffic control notes.

Special Contract Requirement changes

1. *Delete the eighth paragraph of the second Subsection 108.01 of the Special Contract Requirements, page J-10, and substitute the following:*

Do not remove or reclaim more pavement than can be replaced in a work day unless CO approval is obtained. Cover all reclaimed material and aggregate base with a layer of asphalt pavement by the end of the work day. Do not allow reclaimed material or aggregate base to remain exposed for more than one day without CO approval. Remove pavement on days when rain is not in the forecast.

At specific locations with good southern exposure, the CO may approve the use of a temporary traffic signal to close a lane continuously for two days. At these locations reclaimed material and aggregate base may remain uncovered for a maximum of two days.

2. *Delete the second sentence of the first paragraph of Subsection 304.08 of the Special Contract Requirements, page J-37, and substitute the following:*

Do not leave uncompacted aggregate cement mixtures undisturbed for more than 30 minutes, and complete their compaction and finishing within 2 hours from the time water is added.

Plan Sheet changes

1. Delete Plan Sheet 77 and substitute revised Plan Sheet 77.

NPS NO.	REG	STATE	PROJECT	SHEET NO.	TOTAL SHEETS
601 43918	SE	NC	PRA-BLRI-2P14	77	166

TRAFFIC CONTROL NOTES

1. Install appropriate traffic control devices before the inception of construction.
2. Furnish and erect traffic control devices in accordance with the Manual on Uniform Traffic Control Devices (MUTCD), current edition.
3. Construct improvements to overlooks and parking areas concurrently with adjacent Blue Ridge Parkway Improvements. Stagger overlook and parking area construction so no two adjacent areas are closed at the same time.
4. Properly maintain and operate all traffic control devices. Defective traffic control devices are to be replaced as directed by CO.
5. Reset or cover all regulatory warning signs which are no longer appropriate because of construction.
6. Remove all construction traffic control devices immediately upon completion of project.
7. Maintain ingress and egress to all local properties at all times.
8. Maintain a minimum lane width of 9 feet. Use cones to provide the minimum 9 foot lane width, unless directed otherwise by CO.
9. Due to narrow pavement width, close Craggy Garden's Picnic Area Access Road during construction of roadway improvements from the gate located at Sta.19+15 to the picnic area. The Access Road may be closed for construction activities between November and May 20. Between May 21 and July 1, the Access Red is to be open to public use during weekends (Friday 3:00 PM to Monday 6:00 AM). Work on the Access Road and the parking area must be completed by July 15.
10. Night time construction activities are not allowed on the Craggy Garden's Picnic Area Access Road or at the Craggy Garden's Picnic Area to protect endangered / threatened species. Night time is defined as sunset to sunrise.
11. Night time construction activities are allowed on the Parkway.
12. Construct a landing for drum placement at the end of each work day along full depth reclamation or reconstruction areas so that the lane can be opened to traffic. The landing is to tie to the work zone with a slope no greater than a 3:1. Type A or C lights are to be installed on the drums.
13. Pavement is not to be reclaimed or removed on days when rain is forecast.
14. Do not remove or reclaim more pavement than can be replaced in a work day unless CO approval is obtained (see note 15). Cover all reclaimed material and aggregate base with a layer of asphalt pavement by the end of the work day. Do not allow reclaimed material or aggregate base to remain exposed for more than one day without CO approval.
15. At specific locations with good southern exposure, the CO may approve the use of a temporary traffic signal to close a lane continuously for two days. At these locations reclaimed material and aggregate base may remain uncovered for a maximum of two days. Use a temporary traffic signal to regulate traffic at these locations in accordance with Detail E635-A.
16. Do not mill more pavement than can be overlaid with asphalt pavement before noon on Fridays. Use fine milling heads to mill pavement that will be open to traffic.

17. Overlay all pavement patched areas, pavement reconstruction, and reclamation areas with one layer of asphalt pavement prior to opening lane to traffic. Do not allow traffic on aggregate base or reclaimed material.
18. For the work at MP361/40+00+/-, MP362/41+00+/-, and MP363/21+50+/-, supplement the shoulder with aggregate base to provide a minimum 12 foot wide travel lane, as approved by the CO. Work between Monday (6:00 AM) and Friday (12:00 noon).

REVISIONS			
NO.	DESCRIPTION	BY	DATE
2	CLARIFIED NOTES	JW	8/25/08

U.S. DEPARTMENT OF TRANSPORTATION
FEDERAL HIGHWAY ADMINISTRATION
EASTERN FEDERAL LANDS HIGHWAY DIVISION
STERLING, VIRGINIA

BLUE RIDGE PARKWAY
TRAFFIC CONTROL NOTES